



**Supplier Declaration of Conformity**

| Supplier details  |   |
|---|---|
| Name (of New Zealand manufacturer or importer)  | Contact Address   |
| Schneider Electric (NZ) Ltd   | 11 Moncur Place<br>Middleton<br>Christchurch<br>New Zealand   |
| New Zealand Company Number (if applicable)  |   |
| 363533  |   |
| Telephone   | Fax   |
| +64 3 338 9059  | +64 3 339 1624  |
| Email address   |   |
|   |   |
| Medium Risk Article – Details (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable)  |   |
| 2025RCD – Clipsal 2000ser 2X10A, 250V, 50Hz, double pole socket outlet protected by RCD   |   |
| 2025RCD/30 - Clipsal 2000ser. 2X10A switched outlets, 250V, 50Hz, 30mA version  |   |
| 2025RCD/10 - Clipsal 2000ser. 2X10A switched outlets, 250V, 50Hz, 10mA version  |   |
| C2025RCD/30 - Clipsal C2000ser. 2X10A switched outlets, 50Hz, 30mA version  |   |
| C2025RCD/10 - Clipsal C2000ser. 2X10A switched outlets, 50Hz, 10mA version  |   |
| ML2025RCD/30 - Medilec alternative brand name for Clipsal 2025RCD/30  |   |
| ML2025RCD/10 - Medilec - alternative brand name for Clipsal 2025RCD/30  |   |
| The medium risk article listed above, fully complies with the standard(s), as listed:-  |   |
| Standard number & issue year:-<br>AS/NZS 3190 : 2002<br>AS/NZS 3112 : 2004<br>AS/NZS 3133 : 2003<br>AS/NZS 3100 : 2002<br>AS/NZS 3121 : 2002  |   |
| Standard Title:-<br>Approval and test specification - Residual current devices (current-operated earth-leakage devices)<br>Approval and test specification - Plugs and socket-outlets<br>Approval and test specification - Air break switches<br>Approval and test specification - Insulating mouldings<br>Approval and test specification - Insulating mouldings |   |
| Edition / Amendment status:-<br>AS/NZS 3133:2003/Amdt 1:2005<br>AS/NZS 3190:2002/Amdt 1:2002  |   |
| <b>Or complies with the Conformity Cooperation Agreement - Yes / No (Delete as applicable)</b>  |   |
| Names and addresses of any testing organisation or body   |   |
| Name(s)   | Address(es)   |
| International Testing and Certification Services Pty Ltd  | 4-6 Second Street , Bowden, South Australia 5007  |
| Underwriters Laboratories   | 10 Vanadium Place, Middleton, Christchurch New Zealand  |
| Reference to relevant test reports/certification, and issue date of the reports/certification, that show how compliance is achieved:-   |   |
| Report/Certification N <sup>o</sup> (s)   | Issue date(s)   |
| Test Report 13999-00  | 11 <sup>th</sup> June 2008  |
| Test Report 13391-00  | 8 <sup>th</sup> February 2008   |
| Certificate of Approval A 11285   | 29 <sup>th</sup> February 2008  |
| Reference to any management systems involved:-  |   |
| Additional information  |   |
| Declaration   |   |
| We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).<br><br><b>Issuer Identification:</b><br><br><br><br>(as affixed to the article) | <b>Signed for and on behalf of:</b><br>Schneider Electric (NZ) Ltd.   |
|   | <b>Name &amp; position, as authorized by the issuer</b><br>Martin Scottorn<br>Technical Engineer – Marketing ISC                |
|   | <b>Signature</b> <span style="float: right;"><b>Date</b></span>   |
|   |  <span style="float: right;">24-1-11</span> |

For further information please contact Customer Care:  
New Zealand: 0800 652 999  
Australia: 1300 735 329