

## Supplier Declaration of Conformity

### Supplier Details

Name (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

Address

11 Moncur Place  
Middleton  
Christchurch  
New Zealand

Telephone

+64 3 338 9059

Fax

+64 3 339 1657

New Zealand Company Number

363533

### Product Details

Parent Product name, type, model and serial numbers:

56SW2K110 – 56 Series Key-lock Weather Protected Switch






Product variations to the parent model number:

| Abbreviation | Description               |
|--------------|---------------------------|
| GY           | High Impact Grey          |
| RO           | Chemical Resistant Orange |
| RW           | Chemical Resistant White  |
|              |                           |

Ratings:

240 V ~, 50Hz, IP66, 10AX, M50

Additional product information:

|                                  |  |   |
|----------------------------------|--|---|
| Supplier Identification          |    |   |
|                                  | Trade name, Branding or Company name   |   |
| RoHS Compliance                  |   | This product is compliant to European Directive Restriction of Hazardous Substances 2002/95/EC  |
| Regulatory Compliance Mark (RCM) |   | This product complies with all relevant Australian and New Zealand electrical safety standards, including EMC.  |
| Energy Safety Approval No.       | <b>V41</b>   | This product has been issued a Certificate of Approval or Compliance from EnergySafe Victoria, indicating it has been assessed and is suitable and approved for sale in both Australia and New Zealand. |

Documents used as the basis for compliance:

Standards Compliance:

|                  |   |
|------------------|---|
| AS/NZS 3100:2002 | Approval and test specification - General requirements for electrical equipment |
| AS/NZS 3133:2003 | Approval and test specification - Air break switches                            |
| AS/NZS 3133:2008 | Approval and test specification - Air break switches                            |
| AS/NZS 3121:2002 | Approval and test specification - Insulating mouldings                          |
| AS 60529:2001    | Degrees of protection provided by enclosures (IP code)                          |

|  |   |
|--|---|
| AS 60529:2004<br>IEC 60947-3:2008 Ed. 3  | Degrees of protection provided by enclosures (IP code)<br>Low-voltage switchgear and control gear - Part 3 - Switches, disconnect |
| Test Reports & supporting documentation: | R09CA06198B-00<br>R09CA43957-VA00<br>R9725-00<br>R09CA32573-SA01  |
| Certification:                           | 090754/00   |

**Declaration**

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

For further information please contact Customer Care:  
New Zealand: 0800 652 999  
Australia: 1300 735 329

**Signature of Authorised Person**



**Printed Name**

Richard Coia

**Position in Organisation**

Design Supervisor  
Christchurch  
New Zealand

**Date of Declaration**

2<sup>nd</sup> November 2009