

## Supplier Declaration of Conformity

### Supplier Details

**Name** (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

**Address**

11 Moncur Place  
Middleton  
Christchurch  
New Zealand

**Telephone**

+64 3 338 9059

**Fax**

+64 3 339 1657

**New Zealand Company Number**

363533

### Product Details

**Parent Product name, type, model and serial numbers:**

596/56RCD-30  
Fixed Residual Current Device



**Product variations to the parent model number:**

Abbreviation	Description

**Ratings:**

30mA  
230-240V  
IP66  
20A  
50Hz

**Product marking:**

Supplier Identification		
RoHS Compliance		
RCM – EMC Compliance		

**Documents used as the basis for compliance:**

Standards Compliance:

AS/NZS 3190:2002	Approval and test specification – Residual current devices (current operated earth-leakage devices)
AS/NZS 3100:2002	Approval and test specification – General requirements for electrical equipment
AS/NZS 61008.1:2004	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's). Part 1: General rules
AS/NZS CISPR 14.1:2003	Limits and methods of measurement of radio disturbance characteristics of electrical motor-operated and thermal appliances for household and similar purposes, electric tools and similar devices
AS 60529:2004	Degrees of protection provided by enclosures (IP Code)


Test Reports:  
R12525-00  
R12526-00  
R09CA23890-00

Certification:  
090201/00

## Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

### Signature of Authorised Person



### Printed Name

Iain Wickens

### Position in Organisation

Technical Manager  
Christchurch  
New Zealand

### Date of Declaration

22<sup>nd</sup> June 2009