

## Supplier Declaration of Conformity

### Supplier Details

**Name** (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

**Address**

11 Moncur Place  
Middleton  
Christchurch  
New Zealand

**Telephone**

+64 3 338 9059

**Fax**

+64 3 339 1657

**New Zealand Company Number**

363533

### Product Details

**Parent Product name, type, model and serial numbers:**

S825FBABK – Fan Speed Control with Switch

**Product variations to the parent model number:**




| Abbreviation | Description |
|--------------|-------------|
|              |             |

**Ratings:**

Dimmer Ratings: 220-240V a.c, 50Hz, 500W

Switch Ratings: 250V a.c, 16AX,

**Additional product information:**

|                            |   |   |
|----------------------------|---|---|
| Supplier Identification    |  | <br>Trade name, Branding or Company name   |
| RoHS Compliance            |  | This product is compliant to European Directive Restriction of Hazardous Substances 2002/95/EC  |
| C-Tick (EMC)               |  | This product meets the Australian and New Zealand requirements for Electromagnetic Compatibility (EMC).   |
| Energy Safety Approval No. | <b>V41</b>  | This product has been issued a Certificate of Approval or Compliance from EnergySafe Victoria, indicating it has been assessed and is suitable and approved for sale in both Australia and New Zealand. |

**Documents used as the basis for compliance:**

|                        |   |
|------------------------|---|
| Standards Compliance:  |   |
| AS/NZS 3100:2002       | Approval and test specification - General requirements for electrical equipment                                     |
| AS/NZS 3133:2003       | Approval and test specification - Air break switches  |
| AS/NZS 3121:2002       | Approval and test specification - Insulating mouldings  |
| CISPR 15:2000          | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment |
| AS/NZS 60695.2.11:2001 | Fire hazard testing - Glowing/hot wire based test methods - Glow-wire flammability test method for end-products     |

|  |  |
|--|--|
| Test Reports & supporting documentation: | TR2465<br>EMC0327<br>TR4788<br>R9151-00<br>R12301-00 |
| Certification:                           | A/11368E<br>05253/02                                 |

## Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

For further information please contact Customer Care:  
 New Zealand: 0800 652 999  
 Australia: 1300 735 329

**Signature of Authorised Person**



**Printed Name**

Richard Coia

**Position in Organisation**

Technical Manager  
 Christchurch  
 New Zealand

**Date of Declaration**

16<sup>th</sup> February 2010