

## Supplier Declaration of Conformity

### Supplier Details

**Name** (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

**Address**

11 Moncur Place  
Middleton  
Christchurch  
New Zealand

**Telephone**

+64 3 338 9059

**Fax**

+64 3 339 1657

**New Zealand Company Number**

363533

### Product Details

**Parent Product name, type, model and serial numbers:**

56C320RCD-30

56 Series weatherproof fixed wired socket outlet with residual current device protection





**Product variations to the parent model number:**

Abbreviation	Description

**Ratings:**

230 / 240 V ~, 50Hz, IP66, 20A, 30mA Tripping current.

**Additional product information:**

Supplier Identification		 Trade name, Branding or Company name
RoHS Compliance		This product is compliant to European Directive Restriction of Hazardous Substances 2002/95/EC
Regulatory Compliance Mark (RCM)		This product complies with all relevant Australian and New Zealand electrical safety standards, including EMC.
Energy Safety Approval No.	<b>V41</b>	This product has been issued a Certificate of Approval or Compliance from EnergySafe Victoria, indicating it has been assessed and is suitable and approved for sale in both Australia and New Zealand.

**Documents used as the basis for compliance:**

Standards Compliance:	
AS/NZS 3100:2002	Approval and test specification - General requirements for electrical equipment
AS 60529:2004	Degrees of protection provided by enclosures (IP code)
AS/NZS 3190:2009	Approval and test specification - Residual current devices (current operated earth-leakage devices)
AS/NZS 61008.1:2004	Residual current operated circuit-breakers without integral over current protection for household and similar uses (RCCB's) - General rules
CISPR 14-1 Ed 5.0	Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus

AS/NZS 3123:2005	Approval and test specification. Plugs, socket-outlets and couplers for general industrial application
Test Reports & supporting documentation:	R12525-00 R08CA54815-SA01 R12526-00 TR4751-1
Certification:	090781/00

## Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

For further information please contact Customer Care:  
 New Zealand: 0800 652 999  
 Australia: 1300 735 329

**Signature of Authorised Person**



**Printed Name**

Richard Coia

**Position in Organisation**

Technical Manager  
 Christchurch  
 New Zealand

**Date of Declaration**

17<sup>th</sup> December 2009