

Supplier Declaration of Conformity

Supplier Details

Name (of NZ manufacturer, importer or agent)

Schneider Electric (NZ) Ltd

Address

11 Moncur Place
Middleton
Christchurch
New Zealand

Telephone

+64 3 338 9059

Fax

+64 3 339 1657

New Zealand Company Number

363533

Product Details

Parent Product name, type, model and serial numbers:

954 – RCD Protected Cordset (Campers with BALS 4343 Plug)





Product variations to the parent model number:

| Abbreviation | Description |
|--------------|-------------|
| | |

Ratings:

230 / 240 V ~, 50Hz, IP56 RCD and IP44 Plug, 16A, 30mA Tripping current.

Additional product information:

| | | |
|----------------------------|---|---|
| Supplier Identification |   | |
| | Trade name, Branding or Company name | |
| RoHS Compliance |  | This product is compliant to European Directive Restriction of Hazardous Substances 2002/95/EC |
| C-Tick (EMC) |  | This product meets the Australian and New Zealand requirements for Electromagnetic Compatibility (EMC). |
| Energy Safety Approval No. | V41 | This product has been issued a Certificate of Approval or Compliance from EnergySafe Victoria, indicating it has been assessed and is suitable and approved for sale in both Australia and New Zealand. |

Documents used as the basis for compliance:

| | |
|-----------------------|---|
| Standards Compliance: | |
| AS/NZS 3100:2002 | Approval and test specification - General requirements for electrical equipment |
| AS/NZS 3190:2009 | Approval and test specification - Residual current devices (current-operated earth-leakage devices) |
| AS/NZS 61008.1:2004 | Residual current operated circuit-breakers without integral over current protection for household and similar uses (RCCB's) - General rules |
| AS 60529:2004 | Degrees of protection provided by enclosures (IP code) |
| IEC 61543: 1995 | Residual current-operated protective devices (RCD's) for household and similar use - Electromagnetic compatibility |
| AS/NZS 3120:1999 | Approval and test specification - Cord extension sockets |
| AS/NZS 3191:2008 | Electric Flexible Cords |

| | |
|---|--|
| AS/NZS 3112:2004 + A1 DIN EN 60309-1:2007-11 | Approval and test specification - Plugs and socket outlets Plugs, Socket-outlets and Couplers for Industrial purposes. Part 1: General requirements |
| Test Reports & supporting documentation: | R11995-00 R09CA44751-VA00 R08CA63918-SA01 R09CA28399-SA00 40027109 SDOC 0001 |
| Certification: | 090555/01 |

Declaration

We Schneider Electric (NZ) Limited declare under our sole responsibility that the product is in conformity with the relevant clauses of the listed standard(s) or other normative document(s).

Signature of Authorised Person



Printed Name

Richard Coia

Position in Organisation

Technical Manager
Christchurch
New Zealand

Date of Declaration

11th February 2010